



WOOD BLOCKING  
 BACKER ROD AND SEALANT  
 SLOPED SILL  
 MASONRY TIE OR MECHANICAL ANCHOR IN HEAD JOINT  
 RAKE BACK MORTAR BETWEEN UNITS APPROX. 1" DEEP. COVER WITH BACKER ROD AND SEALANT TO PROTECT MORTAR

1-1/2" MIN.  
 1" MIN.  
 UNDERSILL FLASHING MEMBRANE C/W END DAMS, INSTALL TUBE VENTS AT CENTER OF SILL UNIT

INSULATION RETAINER  
 ADJUSTABLE WALL TIE

PREMANUFACTURED THERMALLY BROKEN ALUMINUM WINDOW ASSEMBLY  
 SPRAY APPLIED FOAM INSULATING AIR SEAL ALL AROUND FRAME  
 BACKER ROD AND SEALANT ALL AROUND THE FRAME

WOOD BLOCKING  
 SOLID CONCRETE MASONRY UNIT  
 HORIZONTAL REINFORCING WHEN REQUIRED  
 ASHLAR BLOCK

GYPSUM WALLBOARD, METAL FURRING (OPTIONAL), CONCRETE MASONRY UNIT (CMU), AIRVAPOR BARRIER MEMBRANE, RIGID OR SEMI-RIGID INSULATION (THICKNESS DEPENDANT ON REQUIRED R-VALUE), MIN. 1" AIR SPACE,

DETAIL:  
 WS-B-4  
 REV. 0 (2014)

WATERTABLE WINDOW SILL

