



WOOD BLOCKING

BACKER ROD AND SEALANT

BULLNOSE SILL CALCIUM SILICATE MASONRY UNIT (CSMU)

MASONRY TIE OR MECHANICAL ANCHOR IN HEAD JOINT

RAKE BACK MORTAR BETWEEN UNITS APPROX. 1" DEEP. COVER WITH BACKER ROD AND SEALANT TO PROTECT MORTAR

PREMANUFACTURED THERMALLY BROKEN ALUMINUM WINDOW ASSEMBLY

SPRAY APPLIED FOAM INSULATING AIR SEAL ALL AROUND FRAME

BACKER ROD AND SEALANT ALL AROUND THE FRAME

WOOD BLOCKING

SOLID CONCRETE MASONRY UNIT

HORIZONTAL REINFORCING WHEN REQUIRED

GYPSUM WALLBOARD, METAL FURRING (OPTIONAL), CONCRETE MASONRY UNIT (CMU), AIR/VAPOR BARRIER MEMBRANE, RIGID OR SEMI-RIGID INSULATION (THICKNESS DEPENDANT ON REQUIRED R-VALUE), MIN. 1" AIR SPACE, ADAIR® LIMESTONE MASONRY UNIT.

1" MIN.

UNDERSILL FLASHING MEMBRANE C/W END DAMS, INSTALL TUBE VENTS AT CENTER OF BULLNOSE UNITS

VENT @ 24" O/C

INSULATION RETAINER

ADJUSTABLE WALL TIE



**ARRISCRAFT**  
INTERNATIONAL  
BUILDING STONE • BRICK • LIMESTONE

**ARRISCRAFT • CADD**

TITLE:  
**BULLNOSE WINDOW  
SILL**

DATE DRAWN:  
08/30/04

SCALE:  
3"=1'-0"

DRAWN BY:  
LPS

DETAIL No:  
CB AD12S

**U021**