



MECHANICAL ANCHOR

10  
1

RAKE BACK MORTAR BETWEEN UNITS APPROX. 1" DEEP COVER WITH BACKER ROD AND SEALANT TO PROTECT MORTAR

STONE OR PRECAST CAP

1" MIN.  
1-1/2" MIN.

VENT @ 24" O/C

FLEXIBLE FLASHING MEMBRANE BELOW STONE OR PRECAST CAP

COVERBOARD

VERTICAL REINFORCING IF REQUIRED

ROOF BY OTHER

CALCIUM SILICATE BUILDING STONE, MIN. 1" AIR SPACE, RIGID OR SEMI-RIGID INSULATION (THICKNESS DEPENDANT ON REQUIRED R-VALUE), AIR/VAPOR BARRIER MEMBRANE, CONCRETE MASONRY UNIT (CMU).

FLASHING MEMBRANE SURFACE ADHERE TO SUBSTRATE MORTAR DROP CONTROL

CORROSION PROTECTED CONTINUOUS STEEL ANGLE AND STEEL BRACKET

UNOBSTRUCTED WEEP SYSTEM @ 24" O/C

PREFINISHED METAL DRIP EDGE SET ON TWO BEADS OF SEALANT

3/8" MIN.  
COMPRESSIBLE BACKER ROD AND SEALANT

FLOOR BY OTHER

WELD PLATE CAST IN PLACE



**ARRISCRAFT**  
INTERNATIONAL  
BUILDING STONE • BRICK • LIMESTONE

**ARRISCRAFT • CADD**

TITLE:  
PARAPET TO WALL  
WITH STONE OR PRECAST CAP

DATE DRAWN:  
08/30/04

SCALE:  
3"=1'-0"

DRAWN BY:  
LPS

DETAIL No:  
CB CD3I

**U122**