



HORIZONTAL
REINFORCING
WHEN REQUIRED

HIGH SLUMP
MASONRY GROUT

BUILDING PAPER
(BOND BREAKER)

CALCIUM SILICATE
BUILDING STONE,
MIN. 1" AIR SPACE,
RIGID OR SEMI-RIGID
INSULATION (THICKNESS
DEPENDANT ON
REQUIRED R-VALUE),
AIR/VAPOR BARRIER
MEMBRANE,
CONCRETE MASONRY
UNIT (CMU).

PREFINISHED METAL
FIRESTOPPING ADHERED TO
MASONRY VENEER WITH
CONTINUOUS SEALANT BEAD

PREMOLDED EXPANSION
JOINT FILLER

COMPRESSIBLE BACKER ROD
AND SEALANT

3/8" MIN.

INSULATION RETAINER
ADJUSTABLE WALL TIE



ARRISCRAFT • CADD

TITLE: MOVEMENT JOINT WITH FIRESTOPPING

DATE DRAWN:
08/30/04

SCALE:
3"=1'-0"

DRAWN BY:
LPS

DETAIL No:
CB CD3I
U141