



HORIZONTAL  
REINFORCING  
WHEN REQUIRED

CALCIUM SILICATE  
BUILDING STONE,  
MIN. 1" AIR SPACE,  
RIGID OR SEMI-RIGID  
INSULATION (THICKNESS  
DEPENDANT ON  
REQUIRED R-VALUE),  
AIR/VAPOR BARRIER  
MEMBRANE,  
CONCRETE MASONRY  
UNIT (CMU).

HORIZONTAL REINFORCING  
IN BED JOINTS TO REINFORCE  
CONTINUOUS VERTICAL JOINTS

3/8" MIN.

INSULATION RETAINER

ADJUSTABLE WALL TIE



**ARRISCRAFT • CADD**

TITLE:  
**CONTINUOUS VERTICAL JOINT**

DATE DRAWN:  
08/30/04

SCALE:  
3"=1'-0"

DRAWN BY:  
LPS

DETAIL No:  
CB CD3I

**U142**