



GYPSUM WALLBOARD,
 METAL FURRING (OPTIONAL),
 CONCRETE MASONRY UNIT (CMU),
 AIR/VAPOR BARRIER
 MEMBRANE,
 RIGID OR SEMI-RIGID
 INSULATION (THICKNESS
 DEPENDANT ON REQUIRED
 R-VALUE),
 MIN. 1" AIR SPACE,
 CALCIUM SILICATE BUILDING STONE.

HORIZONTAL REINFORCING
 WHEN REQUIRED

HORIZONTAL REINFORCING
 IN BED JOINTS TO REINFORCE
 CONTINUOUS VERTICAL CORNER JOINTS

RAKE BACK MORTAR BETWEEN UNITS
 APPROX. 1" DEEP. COVER WITH BACKER ROD
 AND SEALANT TO PROTECT MORTAR

INSULATION RETAINER

ADJUSTABLE WALL TIE



ARRISCRAFT • CADD

TITLE:
**OUTSIDE QUIRK
 MITERED CORNER**

DATE DRAWN:
 08/30/04

SCALE:
 3"=1'-0"

DRAWN BY:
 LPS

DETAIL No:
 CB CD3I
U150