

GYPSUM WALLBOARD,
 STEEL STUD WALL,
 EXTERIOR SHEATHING,
 AIR/VAPOR BARRIER MEMBRANE,
 16 GAUGE Z-CHANNEL,
 RIGID OR SEMI RIGID INSULATION
 (THICKNESS DEPENDANT ON
 REQUIRED R-VALUE),
 ALUMINUM CHANNELS,
 1" AIR SPACE,
 CALCIUM SILICATE CLIP UNIT

REQUIRED SHIM TO
 SEPARATE
 ALUMINUM CHANNEL
 FROM Z-CHANNEL, MAX.
 SHIMS 3/4" THICK

BACKER ROD AND
 SEALANT

MINERAL FIBER FIRE
 STOP WHERE REQUIRED

FLASHING MEMBRANE
 ADHERED TO
 SUBSTRATE

COMPRESSIBLE BACKER ROD
 AND SEALANT

UNOBSTRUCTED WEEP
 SYSTEM @ 24" O/C

EXPANSION JOINT REFERENCE
 NOTE IN TOP RIGHT CORNER

WATERPROOFING
 MEMBRANE LEFT LOOSE
 FOR ACCOMODATION OF
 SLAB EDGE MOVEMENT

Z-CHANNEL FASTENERS
 @ 16" O.C. C/W SHIMS AS
 REQUIRED, MAX. SHIMS
 3/4" THICK

ARCHITECT NOTE:

1/2" MINIMUM DEFLECTION SPACE AT
 EACH FLOOR ACCOMMODATES 1/4"
 DISPLACEMENT. WIDER EXPANSION
 JOINTS MAY BE REQUIRED UPON
 ANTICIPATED MOVEMENTS OF
 STRUCTURAL ELEMENTS AND THE
 SEALANT PROPERTIES.

LONG LEG OUTER
 TRACK ANCHORED TO
 SLAB, NEITHER SHEATHING
 OR DRYWALL ATTACHED
 TO ALLOW FOR
 DEFLECTION OF SLAB

NOTE:
 ENSURE FASTENERS ARE 2" MIN
 BELOW DEFLECTION TRACK

3/4" 1/2" 3/4"



ARRISCRAFT
 INTERNATIONAL
 BUILDING STONE • BRICK • LIMESTONE

ARRISCRAFT • CADD

TITLE:
 DEFLECTION SPACE DETAIL

DATE DRAWN:
 01/15/12

SCALE:
 3"=1'-0"

DRAWN BY:
 D.D.N.

DETAIL No:
 SS 12RU

AC080